S. No	Name	Designation	Organization
1	Sh. Asit Singh	Member Secretary	SRPC
2	Sh. V. Balaji	Executive Director	WRLDC
3	Sh. S P Kumar	Executive Director	SRLDC
4	Sh. N Roy	Executive Director	NRLDC
4	Smt. S Usha	Chief General Manager	WRLDC
5	Smt. Pushpa. S	Chief General Manager	WRLDC
6	Sh. Pramod Kumar Prajapati	Deputy General Manager	WRLDC
7	Sh. Vishal Balram Puppala	Manager	WRLDC
8	Sh. Selvamani M	Manager	WRLDC
	Sh.Omkar Kumbhar	Dy.Manager	WRLDC
9	Sh. Somara Lakhra	Chief General Manager	NRLDC
10	Sh. Sunil Kr Aharwal	General Manager	NRLDC
11	Sh. Ankur Gulai	DGM	NRLDC
12	Sh. Ibtesam Asif	Assistant Manager	NRLDC
13	Sh. Kamaldeep Singh	DGM	NRLDC
14	Sh. T Muthukumar	Sr. DGM	SRLDC
15	Sh. T Srinivas	Chief General Manager	SRLDC
16	Sh. A Janardhan	Manager	SRLDC
17	Sh. Vimal		Senvion India

List of the participants joined the meeting virtually on 28.03.2024

List of the participants joined the meeting physically on 28.03.2024

	Grid-India Meeting with RE Associations/ Developers on 28.03 2024					
S. No	Name	Designation	Organisation	Contact	Email	Sign
1	GIRISH DEVESHWAR	POLICY & REGULATORY	SERENTICA RENEWABI	9910105764	givish deverk ward gerenting	ha lin
2	JATIN SHARMA	Regulator-AN	Englinity Global	9983006191	I Shamma @ curlington . 9 lobal.	tent on gu
3	NEELANDONNON MOORYHY	Good com - Spealis.	End Green power	9095921763	noelevanom moth a l	
4	Naresh Kotha	Head OSM	ENEL Green power	8904287870	naresh-kotha@end.com	MA, NO
5	MUKESH KUMAR	Project manage	ENEL Green power	895135478	mukesh. rumar 2. Openel unio	11:110
6	Subrehmagn	CED	NSEFT	7045524527	Publicko Dave Fina	and
7	purnende Kumer Chan	WP, VP,	WIPPA	9897780110	pumendes. Chamber @ Laser.	man Bulling
8	Ashway storme	Hin - Palicy	NSGRI	8750192300	ashiony, sharma Engeti in	the f
9	Manleh Kuhar Tiwari	Regulato TAffens	Blupine Energy	5174075970	manish. Given Stupineewergy. com	And i
10	Naveen Sragh.	Regel chang Alfon	. Oz fower	7985974027	Navera sinel @ 02 Parser in	Daven
11	Kinku Yadar	Manager	Axis Energy	7828752335	Rink D un day a pricance of	6.4
12	Vanshiles Garmer	Policy Associate	NSEFI	83779 20239	vanshin . garner @ needs in	1. Alilier
13	Ashiel Chautan	Arst. Maragor	UPC Reneurables	8810356247	DEHICH, CHRUHRN GUPC P.	Large Diel
14	Sabyarachi Chatteries.	Dy Manager	do-	98933 87446	shinandi al Ilai a	ann Star
15	Lokesh Yadav	Manager	ACME Group	9911972668	Dollach : hatterjeca upo se enewable	als shattern
16	Alchiman Grup La	Manager	Mahindra Suste Roll	9812022202	autor all' Queli Ac	10:2
17	Prashant Kanaujia	Director	Brookfield Renewables	9560690611	Jranauina @ prononergy. com	Allerenard Good-
18	Samath Showhor	Diverti	Service wind .	9999023440		- Pr-
19	Prabhudevogonda Pali	DGM	Suzlon	7350007269	Drabhuderhende na la i	n on . vh
20	Vinod Bishnoi	ST.NP.	Suzion	7714030460	Vhichno' @ Crala. Con	AD
21	Rojesh Kennor	CE	CEA	9873047862	rejest kunov 76 @ we in	(there are a second sec

	Grid-India Meeting with RE Associations/ Developers on 28.03.2024							
S. No	Name	Designation	Organisation	Contact	Email	Sign		
22	RAJIN TORNAL	LIR (SO)	GRID ENON					
23	A-Balan	M(Plg.)	CEA	9483540528	member planning @ gov.in	de n		
24	Swil Singh	AGMLErgg	Eden Renewalle	882238710	Suniel, Sirgh Dedan-	e Sunt		
25	Vikram Gadas	DGMCOSM	1/	9811921434	Vikram. 4a daw adden-ve. con	milicity		
26	Vishal Saxene	AGM (Rg)	Engle India	9650699517	Uishal, saxing d, engre. 10m	(0122)		
27	Andul Kamar	S.M. (Reg)	Hero Fature	9 560 308/64	anchel kumar Chirotectors en	Nerica A.		
28	Agans Kumar	Sm(Reg.)	ReNew	9555905077	agam. Kennes @ serew. com	Alex		
29	Swrayd Barrereke	CGM	GRID- INDIA, NLDC	943304183	sweget barryle grit inlie in	Smi		
30	Manas R. Chand	DGM	Caribindu.	8328864023	manar @ good - Inda . In	Ch		
31	Manish Tyagi	AGM	Jindal Renewasky	9871144602	monish tyaqie jindofrenewood	ele.jo		
32	Abheshek 12, Gupta	SI DEM	Grid-Indra	9869404650	ablasheli@grid-India in			
33	sonali nangal	AM	Goid-India	8561085981	sonalinagal Qgrid-indea. u.	Small		
34	Venuatiesen	SECT DUP	SEC1	990261844)	Venkaleson & Seci-coilo	Dat		
35	Aalook Singh	SECI Mgz	SEQ	991310323	althe singh the alok. sinh (Ceritain Sale		
36	SIVANAROYANA	Gr. Ment-FR	Tata power Reverse	le9717437744	Sivanarayase Otatayower. com	2 Amaganit		
37	Pajam Jan	Manger	End-Judis	959995160+	prizon juin @ grid india . in	h		
38	Prabhanton Porrol	Manages	GRID INDIA	9971702157	ppor web ordination in	explore		
39	Abhiscer Prakag	chrianan	and Indy:	3711931925	applicer @ gid. thelia in	3		
40	RAHUL SHUKLA	Ch. Mgr.	GRID INDIA	9650555388	RAHULSHUKLA @ GRID-INDIA.IN	शहल		
41		·						
42								

v. 31.

8 C 8

Annexure –II

Coordination Meeting with RE Developers



28th March 2024

Grid Controller of India Ltd.

RE Generator - Grid Integration Process





RE Generator - Grid Integration Process



Chronology of CEA Connectivity Standards

Technical Requirements for Solar and Wind Generating Stations

2007 - CEA Technical Standards for Connectivity to the Grid, Regulations 2007

Standards cover **general connectivity conditions for all power system elements (temp.)**, specific requirements for conventional generating units, transmission system & substations, bulk consumers, distribution systems & bulk consumers

2013 - CEA Technical Standards for Connectivity to the Grid, Regulations (Amendment), 2013

- Requirements for solar and wind generating stations included in the standards
- Associated terms such as interconnection point, inverter etc. defined

Major requirements notified for wind and other generating sources with inverter interface:

Power Quality (Harmonic current injection, DC current, Flicker)

Dynamically varying Reactive Power Support (in the range of ±0.95 p.f.)

LVRT (Low Voltage Ride Through) – For wind generating stations connected at 66 kV voltage level or above

2019 - CEA Technical Standards for Connectivity to the Grid, Regulations (Amendment), 2019

- Requirements for **solar and wind generating stations** further **strengthened** in this amendment
 - LVRT Requirement notified for wind as well as other generating units with inverter interface
 - HVRT Requirement notified for wind as well as other generating units with inverter interface

• Other requirements for active power and frequency control also notified

2014 – CERC order in matter of Petition No. 420/MP/2014 directed the wind generating stations to comply with the provisions of CEA Technical Standards for Connectivity Regulations



CERC Regulations (IEGC 2023)

Requirements for Solar and Wind Generating Stations

- Periodic Testing
 - Real and Reactive Power Capability for Generator
 - Power Plant Controller Function Test
 - Frequency Response Test
 - Active Power Set Point change test
 - Reactive Power (Voltage / Power Factor / Q) Set Point change test
- Trial Run Operation
 - Performed for a minimum capacity aggregating to 50 MW* for > 04 hours
 - Requisite metering system, power plant controller, telemetry and protection system to be in service
 - Tests Required Frequency response of machines as per the CEA Standards; Reactive power capability as per OEM rating
- Document Submission
 - Certificate confirming compliance with CEA Technical Standards for Connectivity to the grid regulation
 - Type test report for Fault Ride through Test (LVRT and HVRT)
- All generating units shall have their automatic voltage regulators (AVRs), Power System Stabilizers (PSSs), PIS-SISUI voltage (reactive power) controllers (Power Plant Controller) and any other requirements in operation, as GRID-INDIA per the CEA Technical Standards for Connectivity.

Compliance to provisions of CEA connectivity Standards



nd 🕡 ग्रिड-इंडिया GRID-INDIA

- Compliance to all standards/regulations to be honored
- Provisional approval given only for limited time to comply with reactive power capability and power quality requirements

Common issues observed during Compliance Verification

Test Reports:

- Some of test reports are being submitted with tests carried out as per other standards instead of CEA Technical Standards for Connectivity to the Grid Regulations
- Many important testing parameters such as Short Circuit Ratio (SCR), K-factor for LVRT/HVRT, IBR protection settings, Active Power recovery time after the Fault Ride through (FRT), reactive power response time during FRT are absent in the test reports. In such cases, the requisite information is sought from OEM/RE developers.

Simulation Models:

- Consideration of High Short Circuit ratio (SCR) as compared the actual SCR in the model
- Improper modelling Post fault characteristics, Collector System Network etc.
- Consideration of different LVRT/HVRT K-factors in models in place of implemented value at site
- Non-consideration of communication delays, polling rates/update rates of equipment in modelling
- No/incorrect modelling of relay in simulation model for IBRs, Collector system etc.
- Change in simulation model parameters without proper justification in subsequent submissions



Common issues observed during First Time Charging Process

- Sharing of requisite data for smooth verification of trial run operation
- Delay in PPC Commissioning; Testing of PPC as per IEGC, 2023
- DR (Disturbance Recorder) installation not as per CEA Technical Standards
- Event logger of IBR/WTG are not synchronized with substation SCADA
- Communication protocol (MODBUS) of IBR leading to delay in reporting of event (incorrect sequence of event)



Issues observed during real-time operations

- Inadequate dynamic reactive support from RE plant during grid events and in normal operation
- Delayed active power recovery (90% of pre-fault value within 1 sec)
- Tuning of converter parameter based on realistic consideration of Short Circuit level
- Archival and sharing of inverter/WTG level data during grid event with resolution of 1 ms or better for event analysis
- Protection settings of inverters/WTGs sometimes are not coordinated ensure compliance at POI
- Low Frequency oscillations in voltage/reactive power
- High deviation from schedule for prolonged periods
- Significant deviation observed in performance of some of the plants (during faults) in real-time vis-à-vis simulation response



RE Related Grid Events





Report on Events Involving Transmission Grid Connected Wind & Solar Power Plants

November 2023



- > 31 events involving generation loss of above 1000 MW from renewable power plants - January'22 to May'2023
- Why are these events taking place?
 - Root-cause analysis of the events based on measurement data
 - Analysis supplemented with detailed simulation studies
- Recommendations for changes at equipment, developer, operational and regulatory level





Suggestions and Way Forward

- Monthly coordination meetings to deliberate the pending issues
- Timely submission of requisite data to CTUIL and Grid-India
- Active participation by RE Developers, OEMs, Testing Agencies, Simulation Agencies in the workshop
- Past undertakings and affidavits to be honored by ensuring pending compliances
- Factoring in the effect of cloud, fog, sandstorm etc. in power forecast



Thank you !!



https://grid-india.in/

